



## ADDENDUM #2

CITY OF SPRINGFIELD, MISSOURI  
DIVISION OF PURCHASES  
**INVITATION FOR BID (IFB) #064-2020**  
**FOR: JOY COMPRESSOR INSPECTION & REPAIR**

**RETURN TO:**

Kilina Goldenberg, Buyer  
City of Springfield  
Division of Purchases  
218 E. Central  
Springfield, MO 65802

Date Issued: MARCH 10, 2020  
Buyer's Email: kilina.goldenberg@springfieldmo.gov  
Telephone Number: 417-864-1594  
Fax Number: 417-864-1927  
**REVISED DUE DATE: MONDAY, MARCH 23, 2020 at 3:00 P.M.**

The original **Invitation for Bid #064-2020** for **JOY COMPRESSOR INSPECTION & REPAIR** documents shall remain in effect except as revised by the following changes, which shall take precedence over anything to the contrary in the specifications.

The original bid document for **Invitation for Bid #064-2020** had an original closing date and time of 3:00 P.M. CST., on Wednesday, March 4, 2020, 3:00 P.M. **The bid opening date has been extended until 3:00 P.M. CST., on MONDAY, MARCH 23, 2020.**

**Please Note:** The format of this addendum document will detail questions asked, answers provided, clarifications and statements made and will be denoted as follows: Q=Question, A=Answer, C= Clarification, and S= Statement

Q: What brand and type of controller are used on these units?

A: GE PLC

Q: Are there expectations for the service provider to have programming capabilities for these controllers?

A: No

Q: Will the use of the A-Frame and hoist on site be available to use for any work vendor provides?

A: An employee of the City of Springfield shall be on site to operate the equipment if requested by the vendor. Request must be made three (3) days in advance of scheduled installation. Per Bid Section 3.6.1.6 – All work shall be coordinated through Mark Ryan at 417-838-5131.

Q: Will recent service history records be available to the vendor that wins the bid?

A: Yes

Q: In the addendum #1 specific to the evaluation criteria there is no reference or expectation for OEM (Original Equipment Manufacturer) service provider and genuine OEM parts? Is this important to City of Springfield, if so can the evaluation criteria be amended?

A: No

**ACKNOWLEDGEMENT**

Each bidder shall acknowledge receipt of this **Addendum #2 of Invitation for Bid #064-2020, JOY COMPRESSOR INSPECTION & REPAIR** with his/her signature affixed hereto and shall submit this Addendum and any attachments provided herein with their original bid submittal.

**CERTIFICATION BY BIDDER:**

SIGNATURE: \_\_\_\_\_

TITLE: \_\_\_\_\_

COMPANY: \_\_\_\_\_

DATE: \_\_\_\_\_